


CONDENSER PLATFORM



SPECIFICATIONS

CONSTRUCTION & DESIGN:

- Fabricated from commercial quality Galvalume Steel or .080 Aluminum. Frame members shall be no less than .062".
 - Attachment to SSR Panels using S-5!® Clamps.
 - Pitched Corrected for sloped roofs.
 - Multiple units can be installed in series.
 - Adjustable widths for field locations.
 - Finish to be mill. Painted to match roof optional.



CALL FOR CURRENT PRICING



DESIGN COMPONENTS, INC. Serving The Metal Building Industry Since 1978

115 Walter Way	Fayetteville, GA 30214	email: sales@designcomponents.com
PH (800) 868-9910	FX (770) 460-7872	website: www.designcomponents.com

INSTALLATION DETAILS



1. Locate each Rib Cap on to Standing Seam Rib.



2. Fasten Frame Channels to Rib Bracket with 3/4" Tek Screws. Two per Rib Bracket.



3. Assemble S-5!® and place over notched ends of rib caps.



4. Tighten Clamp Bolts on S-5!®'s. Follow separate instructions for S-5!® Clamps.



5. Locate Platform Channels to fit equipment to be mounted. Top of Platform Channels should be level. Fasten with 3/4" Tek Screws through holes provided.



DESIGN COMPONENTS, INC. Serving The Metal Building Industry Since 1978

115 Walter Way	Fayetteville, GA 30214	email: sales@designcomponents.com
PH (800) 868-9910	FX (770) 460-7872	website: www.designcomponents.com